



Clearwater Regional Fire Rescue Services


For Further Inquires Call:
403-845-4444

Serving the Municipalities of

Clearwater County / Town of Rocky Mountain House / Village of Caroline

Residential Recreation - Fire Pit Guidelines

Plan View



Requirement: Minimum of 3 meters (10 feet) clearance (6m desired) from all trees (including overhanging branches) shrubs and combustible structures (Buildings / Fences) & property lines. Inclusion of fire pit with decks and patios must comply with the regulations for materials and clearances as required by the Alberta Building Code for fireplaces.

Recommendation: Minimum of .5 m (24 inch) wide apron of non-combustible material such as concrete, gravel, shale or sand

Requirement: Maximum 1 m (36 in) inside diameter concrete, brick or steel


Requirement: arrestor grate (mesh spacing not greater than 1.25 cm or ½ inch

Recommendation: Steel fire spark arrestor grate (mesh spacing not greater than 7 mm or ¼ inch

Recommendation: Minimum 15 cm (6 in) non-combustible cover over organic soil

Requirement: Minimum .6 m (24 in) above existing grade

Recommendation: Non-combustible apron



Safety Recommendation

DO NOT place the Pit over or under utilities such as Gas or Power lines

Call before you dig (Alberta First Call – 1-800-242-3447)